



**Mevr. Evelyne Martin**  
**Associated Weavers Europe**  
**Industriezone 1**  
**9600 RONSE**

**Your message - reference**

-

**our reference**

PW/2196

**Gent**

2021-08-20

## Certification report 21/2196

---

### 1. Description of the flooring:

<b>Product family</b>	Tufted broadloom carpet 100% polyester Fusion Backing
<b>Total mass</b>	1850 g/m <sup>2</sup> - 2995 g/m <sup>2</sup>
<b>Effective pile thickness</b>	6.0 mm – 16.6 mm

### 2. Test results:

#### Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C <sub>fl</sub>	E <sub>fl</sub>	heat flux $\geq$ 4.5 kW/m <sup>2</sup>

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

**CENTEXBEL • textile competence centre • [www.centexbel.be](http://www.centexbel.be)**

**GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • [gent@centexbel.be](mailto:gent@centexbel.be)**

**VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB**

**addressee**

Associated Weavers Europe

**our reference**

PW/1926

**Gent**

2020-09-08

**page**

2

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate<sup>1</sup>

Cfl - s1

**Related commercial names to this product group**

Solstice  
Meridia  
Dorado  
Tigris  
Softissimo  
Equinox  
Canopee  
Savitri  
Equator  
Indus  
Ganges  
Nile  
Eclipse

**The obtained classification is based on the next test reports**

Centexbel: 18.00889.01 dd 2018-03-29  
Centexbel: 18.02099.01 dd. 2018-05-24  
Centexbel: 18.04635.01 dd. 2018-09-17

**Validity of the certificate**

2023-05-23

Petra Wittevrongel  
Product Certifier

<sup>1</sup> End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)