

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-24-03-01-02

Products: Laminate floor coverings DPL 6 mm -14 mm

Producer: KRONOSPAN GmbH Lampertswalde, Mühlbacher Straße 1, 01561 Lampertswalde

Order: Testing and classification of selected properties according to EN 14041:2004+AC:2005+AC:2006 (CE labelling)

Test reports: 2117133/2023/3/W/1

Test results:

Property	Result	Declaration according to EN 14041:2004 +AC:2005+AC:2006
Reaction to fire performance according to EN ISO 9239-1:2010-06 and EN ISO 11925-2:2020-03; Classification according to EN 13501-1:2018-12 - Critical heat flux - Smoke production	6,5 kW / m ² 14 % x min	C _{fi} -s1*
Electrostatic behaviour according to EN 1815:2016-09	Body voltage = 0,3 kV	Antistatic Floor Covering

* Valid on mineral subfloor in end use application, using adhesives or not.

Dresden, 01/03/2024



P.P. R. Pisch
Head of laboratory

A. P. K.
Engineer in charge