



CREATUFT NV
Industrielaan 16
8520 KUURNE

Your message - reference

-

our reference

PW/1014

Gent

2022-03-31

Certification report 22/1014

1. Description of the flooring:

Product family	Tufted broadloom carpet >80% wool - <20% polyamide Woven textile backing: jute
Total mass	1850 g/m ² - 3280 g/m ²
Effective pile thickness	3.4 mm – 7.7 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C _{fl}	E _{fl}	heat flux ≥ 4.5 kW/m ²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB



addressee

CREATUFT NV

our reference

PW/1014

Gent

2022-03-31

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

glued on a non-combustible substrate¹

Cfl - s1

Related commercial names to this product group	Dublin Leeds Windsor Candy stripe Casablanca Tanger Fez Alfa Berlin Sydney Wellington Sheba	Ceres Taiga London Amsterdam Greenwich Oxford Malta Hawai Aran Titan Bellagio Savanna Himalaya
The obtained classification is based on the next test reports	UGent: 20-0724-01 dd 2020-08-24 Centexbel: 21.06892.03 dd 2021-12-17 Centexbel: 21.06892.04 dd 2021-12-17 Centexbel: 21.06892.05 dd 2021-12-17	
Validity of the certificate	2025-08-24	

Petra Wittevrongel
Product Certifier

¹ End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)